

ADDENDUM #1

Date: November 24, 2021

To: All Bidders

From Tracy Shattuck
PDA-DPH

Re: **Addendum #1**
Pease Development Authority – Division of Ports & Harbors
Trailer Mounted Diesel Generator System
Portsmouth, New Hampshire

Addendum #1 is generally intended to address an additional question from a bidders:

Bidders' questions followed by responses in bold and italics as follows:

Question 1 - In reading the specifications it appears only one voltage is called for on the generators, that being 120/240 3 phase. Is this correct, or is selectable voltage required? It is very unusual to have a mobile generator with just one voltage which is the reason for the question.

Answer 1- A review of the" Technical Specifications for Trailer Mounted Diesel Generator System" was completed and it was determined that Section 1.3 E should be changed to read as follows:

1.3 SYSTEM DESCRIPTION

E. System Capacity – A manufacturer's standard nominal 55 kW/60 kVA standby rating at 0.8 power factor, **240v/120v single phase and 208v / 120v three phase 60Hz** ~~120/240 volts, 3 phase, 60 Hz~~ at generator speed of 1800 RPM, It is the intent that the generator be a model and type conforming to a standard production unit meeting or exceeding the performance specified.

Please acknowledge receipt of this Addendum by signing below and faxing back to PDA-DPH at 603-436-2780 or email to b.therrien@peasedev.org no later than 3:00 PM on Friday, November 26, 2021.

Also, you must acknowledge receipt of Addendum #1 on the Bid Form.

Company Name

Printed Name of Authorized Signer

Authorized Signer